

WEST MORRIS REGIONAL HIGH SCHOOL DISTRICT

ADMINISTRATION BUILDING • 10 SOUTH FOUR BRIDGES ROAD
CHESTER, NEW JERSEY 07930 • 908-879-6404 Fax: 908-879-8861

October 13, 2016

L. DOUGLAS PECHANEC
BUSINESS ADMINISTRATOR / BOARD SECRETARY

To the West Morris Regional High School District Community:

We are providing the following documents as an update to the recent lead testing of our two high schools.

- Initial notification letters - [WM Central](#) [WM Mendham](#)
(Originally sent out and posted on September 21, 2016, to our District and school websites)
- [Complete testing report](#) - provided by Precision Analytical Services, Inc.
- [Subsequent flushing report](#) - provided by Precision Analytical Services, Inc.
- [Brief overview of the testing process](#) - provided by Garden State Environmental

We tested 62 fixtures at WM Central and 50 fixtures at WM Mendham. The initial report indicated elevations above the PPB, Parts Per Billion, the EPA “Action Level” for a first draw sample, in 7 locations within the District: one at WM Central and six at WM Mendham. We immediately took those water fixtures out of service. Last Friday we received the flushing report indicating that all fixtures that were above 15.5 PPB in the first sampling after the flushing process, (i.e. run water for 30 seconds or more) were **below** 15.5 PPB.

Our next steps will be to take remedial actions to ensure that water quality throughout our facilities is safe for all.

Sincerely,

L. Douglas Pechanec